



State of Florida

Okaloosa County Public Works



December 12, 2014

**Re: ADDENDUM No. 1 - RFB PW 12-15
Okaloosa County Department of Corrections Parking Lot Repair
Bid Opening: Wednesday, December 17, 2014 @ 2:00 PM (CST)**

This addendum addresses concerns from the mandatory pre-bid meeting held on Tuesday, December 2, 2014 and any subsequent questions/comments that were submitted by December 10, 2014.

1. No NPDES permit will be required for this project.
2. The Contractor will be required to pull an electrical permit from Okaloosa Co. Growth Management for the lighting repairs.
3. Bid Schedule Revisions:

Item No. 8 (Spec 285-1) - 6" Sand Clay Base has been revised to "**Optional Base Group 4 (6" Crushed Concrete)**"

Item No. 9 (Spec 334-1) - 2" Superpave Asphalt has been revised to "**2" Superpave Asphalt (Traffic Level C)**".

(A revised Bid Schedule is attached for your convenience.)

Eric Broome, P.E.
County Project Manager

Email Cc:
All Pre-Bid Meeting Attendees
Rob Vandebroek, PW Operations Manager
Tonia Nation, P.E., EOR, Avcon, Inc.
Joanne Kublik, Okaloosa County Purchasing

BID SCHEDULE – OKALOOSA CO. CORRECTIONS PARKING LOT REPAIR

ITEM NO.	FDOT SPECIFICATION	ITEM DESCRIPTION	UNIT	QUANTITY	UNIT PRICE	TOTAL
1	101-1	MOBILIZATION	LS	1	\$ _____	\$ _____
2	102-1	MAINTENANCE OF TRAFFIC	LS	1	\$ _____	\$ _____
3	104-1	EROSION CONTROL	LS	1	\$ _____	\$ _____
4	110-1	MISCELLANEOUS DEMOLITION	LS	1	\$ _____	\$ _____
5	120-1	EXCAVATION	CY	145	\$ _____	\$ _____
6	120-2	EMBANKMENT	CY	175	\$ _____	\$ _____
7	120-3	SUBGRADE PREPARATION	SY	850	\$ _____	\$ _____
8	285-1	OPTIONAL BASE GROUP 4 (6" CRUSHED CONCRETE)	SY	200	\$ _____	\$ _____
9	334-1	2" SUPERPAVE ASPHALT (TRAFFIC LEVEL C)	TN	100	\$ _____	\$ _____
10	350-1	CONCRETE FLUME	EA	1	\$ _____	\$ _____
11	520-1	TYPE F CURB & GUTTER	LF	224	\$ _____	\$ _____
12	548-1	MASONRY RETAINING WALL (HEIGHT VARIES)	LF	212	\$ _____	\$ _____
13	550-2	8' HIGH CHAIN LINK FENCE POST INSTALLATION (REUSE EXISTING FABRIC)	LF	325	\$ _____	\$ _____
14	550-2	3' HIGH CHAIN LINK FENCE REALIGNMENT (REUSE EXISTING FABRIC)	LF	244	\$ _____	\$ _____
15	710-1	PARKING LOT MARKINGS	SF	148	\$ _____	\$ _____
16	981-1	SOD, BAHIA ARGENTINA	SY	755	\$ _____	\$ _____
17	16010-1	LIGHTING REPAIR	LS	1	\$ _____	\$ _____
				TOTAL		\$ _____