

Addendum #6

RFB FM/AP Fire Suppression
(Replaces page 6)

- EMS Supply Building – Fort Walton Beach
 - Courthouse Annex Extension – Fort Walton Beach
 - Water and Sewer Maintenance Building – Crestview
 - Coordinated Transportation Building – Fort Walton Beach
- 2. Annual Fire Alarm and Duress Monitoring:**
- Tourist Development Center - Okaloosa Island
 - Health Department – Crestview
 - Health Department – Fort Walton Beach
 - Courthouse – Crestview
 - Water and Sewer Pump Building – Fort Walton Beach
 - Water and Sewer Building – Fort Walton Beach
 - Coordinated Transportation Building – Fort Walton Beach
 - Clerks Record Storage – Both Crestview locations
 - Arbennie Prichett Sewer Plant – Fort Walton Beach
 - EMS Supply Building – Fort Walton Beach
 - Pre-Trial Services – Crestview Manor, Crestview
 - Emerald Coast Convention Center – Okaloosa Island
 - Courthouse Annex Extension – Fort Walton Beach
- 3. Fire Pump Inspections:**
- Courthouse Annex Extension – Fort Walton Beach

Additional locations may be added to the contract as approved by the County.

The list of the Okaloosa County System of Airports locations are as follows:

- The Northwest Florida Regional Airport (VPS), Valparaiso
 - Main Building
 - Airport Cargo Building
 - Airport Car Rental
 - Car Fuel Site
- Bob Sikes Airport (CEW), Crestview
- Destin/Fort Walton Airport (DTS), Fort Walton Beach

Additional locations may be added to the contract as approved by the County.

The following list of inspections will be required:

Annual/Semi-Annual/Quarterly Inspections:

- All fire extinguishers are to be inspected on an annual basis.
- All kitchen hood suppression systems are to be inspected semi-annually.
- All fire sprinkler systems are to be inspected annually and quarterly.
- Annual, Semiannual, and Quarterly Inspections
- Annual Fire Alarm Inspections
- Fire Line and Domestic Backflow Inspections
- Annual Fire Alarm and Duress Monitoring
- Fire Pumps Inspections Weekly